

Question on Notice
No. 709
Asked on Friday, 24 June 2022

MR P WEIR ASKED MINISTER FOR ENERGY, RENEWABLES AND HYDROGEN AND MINISTER FOR PUBLIC WORKS AND PROCUREMENT (HON M DE BRENNI)

Will the Minister advise how many unplanned outages have occurred at Stanwell Corporation and CS Energy generation assets to date in 2022?

ANSWER

In the period 1 January 2022 to 24 June 2022 Stanwell Corporation has reported seven unplanned outages across its portfolio of nine coal fired generating units.

In the period 1 January 2022 to 24 June 2022 CS Energy has reported eight unplanned outages across its portfolio of five coal fired generating units. This number is inclusive of the Callide Unit C4 unplanned outage which commenced in May 2021, as result of fire damage.